
Summer 2001 Radon Tests

	<i>Room Number</i>	<i>Test start date</i>	<i>Test finish date</i>	<i>Result (pCi/l)</i>
<i>ABERNETHY</i>				
	4	7/3/2001	7/6/2001	0.2
<i>APLEGATE</i>				
	6	7/3/2001	7/6/2001	0.3
<i>ARLETA</i>				
	35	7/3/2001	7/6/2001	0.2
	4	7/3/2001	7/6/2001	0.2
	5	7/3/2001	7/6/2001	0.2
	9	7/3/2001	7/6/2001	0.2
<i>ASTOR</i>				
	11	7/3/2001	7/6/2001	1.2
	18	7/3/2001	7/6/2001	1.5
	19	7/3/2001	7/6/2001	1
	20	7/3/2001	7/6/2001	0.9
	21	7/3/2001	7/6/2001	1.6
	25	7/3/2001	7/6/2001	0.5
	50	7/3/2001	7/6/2001	0.8
	6	7/3/2001	7/6/2001	0.3
	7	7/3/2001	7/6/2001	0.3
	9	7/3/2001	7/6/2001	0.5
<i>BEACH</i>				
	114	7/10/2001	7/13/2001	0.2
	13A	7/10/2001	7/13/2001	0.2
	21	7/10/2001	7/13/2001	0.2
	22	7/10/2001	7/13/2001	0.3
	B22	7/10/2001	7/13/2001	0.2

<i>Room Number</i>	<i>Test start date</i>	<i>Test finish date</i>	<i>Result (pCi/l)</i>
<i>BEAUMONT</i>			
11A	8/7/2001	8/10/2001	2.4
11A	8/7/2001	8/10/2001	2.5
12A	8/7/2001	8/10/2001	0.9
13A	8/7/2001	8/10/2001	1.2
14A	8/7/2001	8/10/2001	1.4
16A	8/22/2001	8/24/2001	0.5
16C	8/22/2001	8/24/2001	0.5
<i>BENSON</i>			
G12 Weight Room	7/3/2001	7/6/2001	0.4
<i>BINNSMEAD</i>			
168	7/3/2001	7/6/2001	0.5
189	7/3/2001	7/6/2001	0.4
189	7/3/2001	7/6/2001	0.2
<i>BUCKMAN</i>			
106	7/3/2001	7/6/2001	0.6
<i>CHAPMAN</i>			
K PORTABLE	7/11/2001	7/13/2001	0.5
K2	7/11/2001	7/13/2001	0.4
K4	7/11/2001	7/13/2001	0.2
K5	7/11/2001	7/13/2001	0.5
<i>CHIEF JOSEPH</i>			
11	7/11/2001	7/13/2001	0.8
12	7/11/2001	7/13/2001	0.4
LIBRARY	7/11/2001	7/13/2001	1.7

<i>Room Number</i>	<i>Test start date</i>	<i>Test finish date</i>	<i>Result (pCi/l)</i>
<i>COLUMBIA TRANSPORTATI</i>			
12	11/13/2001	11/16/2001	0.2
12A	9/18/2001	9/21/2001	1.8
13	11/13/2001	11/16/2001	0.2
13A	9/18/2001	9/21/2001	6.8
13B	11/13/2001	11/16/2001	0.2
14	11/13/2001	11/16/2001	0.1
14A	10/2/2001	10/5/2001	1.1
14A	11/13/2001	11/16/2001	0.2
15	11/13/2001	11/16/2001	0.1
15A	9/18/2001	9/21/2001	2.7
16	7/24/2001	7/27/2001	3.1
B2	9/18/2001	9/21/2001	0.8
B3	9/18/2001	9/21/2001	0.1
Boiler rm	10/2/2001	10/5/2001	1.1
Bus Gar - Brk rm	9/18/2001	9/21/2001	0.8
<i>CRESTON</i>			
111	7/11/2001	7/13/2001	0.2
MEDIA CENTER	7/10/2001	7/13/2001	1
<i>CSC</i>			
3	8/7/2001	8/10/2001	0.5
G27	8/7/2001	8/10/2001	0.3

<i>Room Number</i>	<i>Test start date</i>	<i>Test finish date</i>	<i>Result (pCi/l)</i>
<i>DIVISION STREET</i>			
14	8/6/2001	8/9/2001	0.4
15	8/6/2001	8/9/2001	0.7
22	8/6/2001	8/9/2001	0.4
24	8/6/2001	8/9/2001	0.8
26	8/6/2001	8/9/2001	0.2
33	8/2/2001	8/6/2001	1.5
39	8/2/2001	8/6/2001	0.7
40	8/2/2001	8/6/2001	0.8
41	8/2/2001	8/6/2001	0.9
42	8/2/2001	8/6/2001	1.4
43	8/2/2001	8/6/2001	1.3
44	8/2/2001	8/6/2001	2.5
45	8/2/2001	8/6/2001	2
50	8/2/2001	8/6/2001	0.8
56	8/2/2001	8/6/2001	0.9
59	8/2/2001	8/6/2001	0.6
60	8/2/2001	8/6/2001	0.6
62	8/2/2001	8/6/2001	1.1
69	8/6/2001	8/9/2001	0.7
70	8/6/2001	8/9/2001	0.2
78	8/6/2001	8/9/2001	0.4
8	8/6/2001	8/9/2001	0.5
82	8/6/2001	8/9/2001	0.5
B1	8/2/2001	8/6/2001	2.1
<i>FOSTER</i>			
CL4	8/7/2001	8/9/2001	0.7
CL5	8/7/2001	8/9/2001	1.1
<i>GRANT</i>			
13	7/10/2001	7/13/2001	0.2
43	7/10/2001	7/13/2001	0.2
S12	7/10/2001	7/13/2001	0.2

<i>Room Number</i>	<i>Test start date</i>	<i>Test finish date</i>	<i>Result (pCi/l)</i>
<i>GREGORY HEIGHTS</i>			
006	8/28/2001	8/30/2001	0.6
007	8/28/2001	8/30/2001	1.1
166	11/13/2001	11/16/2001	0.3
167	11/13/2001	11/16/2001	0.2
168	11/13/2001	11/16/2001	0.2
170	11/13/2001	11/16/2001	0.9
175	11/13/2001	11/16/2001	0.2
177	11/13/2001	11/16/2001	0.4
181	11/13/2001	11/16/2001	2.7
<i>GROUT</i>			
13	7/10/2001	7/13/2001	0.2
B	7/10/2001	7/13/2001	0.2
C	7/10/2001	7/13/2001	0.2
D	7/10/2001	7/13/2001	0.3
<i>HAYHURST</i>			
18	7/11/2001	7/13/2001	0.2
<i>HOSFORD</i>			
101	7/10/2001	7/13/2001	0.2
<i>JAMES JOHN</i>			
29	7/10/2001	7/13/2001	0.2
37	7/10/2001	7/13/2001	0.3
42	8/7/2001	8/9/2001	1.2
42A	7/10/2001	7/13/2001	0.4
<i>KELLOGG</i>			
104	8/7/2001	8/10/2001	0.5
138	7/17/2001	7/20/2001	0.2

	<i>Room Number</i>	<i>Test start date</i>	<i>Test finish date</i>	<i>Result (pCi/l)</i>
<i>KELLY</i>				
	101	8/7/2001	8/10/2001	0.2
	102	8/7/2001	8/10/2001	0.2
	109	8/7/2001	8/10/2001	0.3
	110	8/7/2001	8/10/2001	0.2
	111	8/7/2001	8/10/2001	0.5
	117	8/7/2001	8/10/2001	1.4
	122	8/28/2001	8/30/2001	0.2
	123	8/28/2001	8/30/2001	0.3
	124	8/28/2001	8/30/2001	0.2
	125	8/28/2001	8/30/2001	0.2
	126	8/28/2001	8/30/2001	0.2
	127	8/28/2001	8/30/2001	0.2
<i>KENTON</i>				
	A	8/7/2001	8/9/2001	0.5
<i>LAURELHURST</i>				
	1	7/17/2001	7/20/2001	1.2
	112	7/17/2001	7/20/2001	2
	2	7/17/2001	7/20/2001	0.8
	3	7/17/2001	7/20/2001	0.9
	4	7/17/2001	7/20/2001	0.7
<i>LENT</i>				
	121	7/25/2001	7/27/2001	0.4
	146	7/25/2001	7/27/2001	0.5
	152	7/25/2001	7/27/2001	0.3
<i>LEWIS</i>				
	12	8/7/2001	8/10/2001	0.2
	13	8/7/2001	8/10/2001	0.2
	22	8/7/2001	8/10/2001	0.4
<i>LINCOLN</i>				
	71C	8/7/2001	8/10/2001	0.2
<i>MARSHALL</i>				
	AUTO SHOP A 21	7/17/2001	7/20/2001	0.2
	AUTO SHOP A 40	7/17/2001	7/20/2001	0.3

	<i>Room Number</i>	<i>Test start date</i>	<i>Test finish date</i>	<i>Result (pCi/l)</i>
<i>MARSHALL</i>				
	MEDIA CENTER	7/10/2001	7/13/2001	1.2
<i>MARYSVILLE</i>				
	014	7/31/2001	8/3/2001	1.2
<i>MEEK</i>				
	103	7/24/2001	7/27/2001	0.2
	105	7/24/2001	7/27/2001	0.9
	107	7/24/2001	7/27/2001	1.3
<i>MONROE</i>				
	107	7/24/2001	7/27/2001	0.4
<i>MT. TABOR</i>				
	204	8/7/2001	8/10/2001	0.2
<i>OCKLEY GREEN</i>				
	142	8/7/2001	8/9/2001	0.4
<i>PORTSMOUTH</i>				
	011	7/31/2001	8/3/2001	1.6
	019	7/31/2001	8/3/2001	2
	023	7/31/2001	8/3/2001	2.5
	115	7/31/2001	8/3/2001	1
	174	7/31/2001	8/3/2001	1.9
<i>RICHMOND</i>				
	24	7/25/2001	7/27/2001	0.6
<i>ROOSEVELT</i>				
	103	7/24/2001	7/27/2001	1.4
	152	7/24/2001	7/27/2001	1.9
	M149	7/24/2001	7/27/2001	4.7
	METAL SHOP	7/24/2001	7/27/2001	2.3
<i>ROSE CITY PARK</i>				
	16	7/24/2001	7/27/2001	1.5
<i>SABIN</i>				
	200A	7/24/2001	7/27/2001	0.5
	220B	7/24/2001	7/27/2001	0.2

	<i>Room Number</i>	<i>Test start date</i>	<i>Test finish date</i>	<i>Result (pCi/l)</i>
<i>SITTON</i>				
	3	7/31/2001	8/3/2001	0.2
	MUSIC ROOM	7/31/2001	8/3/2001	0.2
<i>SKYLINE</i>				
	105B	8/1/2001	8/3/2001	2.7
<i>SUNNYSIDE</i>				
	LIBRARY	7/31/2001	8/3/2001	0.2
<i>VERNON</i>				
	108	7/31/2001	8/3/2001	2.6
	109	7/31/2001	8/3/2001	2.8
	114	7/31/2001	8/3/2001	2.2
	115	7/31/2001	8/3/2001	1.6
<i>VESTAL</i>				
	112	7/31/2001	8/3/2001	0.2
<i>VOCATIONAL VILLAGE</i>				
	136	8/27/2001	8/30/2001	1.7
	138	8/7/2001	8/10/2001	0.2
	142	8/7/2001	8/10/2001	0.9
<i>WEST SYLVAN</i>				
	10	8/7/2001	8/10/2001	0.3
	104	8/7/2001	8/10/2001	0.2
	11	8/7/2001	8/10/2001	0.2
	130	8/7/2001	8/10/2001	0.2
	144	8/7/2001	8/10/2001	0.4
	157	8/7/2001	8/10/2001	0.5

<i>Room Number</i>	<i>Test start date</i>	<i>Test finish date</i>	<i>Result (pCi/l)</i>
<i>WHITAKER HOLDING</i>			
1	7/20/2001	7/24/2001	0.9
101	7/20/2001	7/24/2001	2.2
102	7/20/2001	7/23/2001	1.1
103	7/20/2001	7/24/2001	0.7
104	7/20/2001	7/23/2001	1
105	7/20/2001	7/23/2001	0.4
106	7/20/2001	7/24/2001	3.5
107	8/20/2001	8/23/2001	2
205	7/20/2001	7/23/2001	0.5
6	7/20/2001	7/24/2001	1.7
BOILER ROOM	7/20/2001	7/23/2001	1.3
Center room	7/20/2001	7/24/2001	0.7
LIBRARY	7/20/2001	7/23/2001	0.4
Resourse room	7/20/2001	7/24/2001	1.8
WORK ROOM	7/20/2001	7/23/2001	1.4
<i>WHITMAN</i>			
010	7/31/2001	8/3/2001	0.3
022	7/31/2001	8/3/2001	0.5
04	7/31/2001	8/3/2001	0.3
<i>WOODSTOCK</i>			
26	7/31/2001	8/3/2001	0.2
<i>YOUNGSON</i>			
012	7/3/2001	8/3/2001	0.2
02	7/3/2001	8/3/2001	0.4

Update: Portland Public Schools Radon Testing Program Results

<i>NAME</i>	<i>Room Number</i>	<i>Start date</i>	<i>Finish date</i>	<i>Result (pCi/l)</i>	<i>Type of Test*</i>	<i>Comments</i>
<i>LEE</i>						
	100	11/30/2001	7/3/2002	2.4	Alpha track	
	100a	11/30/2001	7/3/2002	2.5	Alpha track	
	101	11/30/2001	7/3/2002	3.3	Alpha track	
	101a	11/30/2001	7/3/2002	2.7	Alpha track	
	102	11/30/2001	7/3/2002	2.1	Alpha track	
	103	11/30/2001	7/3/2002	2.1	Alpha track	
	104	11/30/2001	7/3/2002	1.6	Alpha track	
	105	11/30/2001	7/3/2001	1.4	Alpha track	
	106	11/30/2001	7/3/2002	1.5	Alpha track	
	107	11/30/2001	7/3/2002	2	Alpha track	
	108	11/30/2001	7/3/2002	1.3	Alpha track	
	109	11/30/2001	7/3/2002	2	Alpha track	
	110	11/30/2001	7/3/2002	1.1	Alpha track	
	111	11/30/2001	7/3/2002	1.3	Alpha track	
	112	11/30/2001	7/3/2002	0.9	Alpha track	
	113	11/30/2001	7/3/2002	0.4	Alpha track	
	114	11/30/2001	7/3/2002	1.3	Alpha track	
	115	11/30/2001	7/3/2002	2.1	Alpha track	

**Alpha Track monitors provide the long term average radon level 24 hours a day, 7 days a week for 6 - 7 months. That includes time when schools are closed and the ventilation system is off (nights, weekends and holidays).*

**Continuous monitors provide average hourly radon levels over 3 - 4 days. They allow us to see how the ventilation system affects the radon level. Continuous monitors were placed in all locations where Alpha Track monitors had a result at 4.0 pCi/l or higher.*

Update: Portland Public Schools Radon Testing Program Results

<i>NAME</i>	<i>Room Number</i>	<i>Start date</i>	<i>Finish date</i>	<i>Result (pCi/l)</i>	<i>Type of Test*</i>	<i>Comments</i>
	116	11/30/2001	7/3/2002	1.8	Alpha track	
	117	11/30/2001	7/3/2002	2.7	Alpha track	
	118	11/30/2001	7/3/2002	2.3	Alpha track	
	119	11/30/2001	7/3/2002	0.9	Alpha track	
	120	11/30/2001	7/3/2002	3	Alpha track	
	121	11/30/2001	7/3/2002	3.1	Alpha track	
	122	11/30/2001	7/3/2002	1.8	Alpha track	
	123	11/30/2001	7/2/2002	0.8	Alpha track	
	Blank			0.5	Alpha track	
	Boiler room	11/30/2001	7/3/2002	0.8	Alpha track	
	CI5	11/30/2001	7/3/2002	1.3	Alpha track	
	Faculty dining	11/30/2001	7/3/2002	1.6	Alpha track	
	Gym	11/30/2001	7/3/2002	1.1	Alpha track	
	Kitchen	11/30/2001	7/3/2002	1.1	Alpha track	
	Main office	11/30/2001	7/3/2002	1.5	Alpha track	

Samples for 2002 Baseline: 33

END RESULTS FOR LEE

**Alpha Track monitors provide the long term average radon level 24 hours a day, 7 days a week for 6 - 7 months. That includes time when schools are closed and the ventilation system is off (nights, weekends and holidays).*

**Continuous monitors provide average hourly radon levels over 3 - 4 days. They allow us to see how the ventilation system affects the radon level. Continuous monitors were placed in all locations where Alpha Track monitors had a result at 4.0 pCi/l or higher.*

Update: Portland Public Schools Radon Testing Program Results

<i>NAME</i>	<i>Room Number</i>	<i>Start date</i>	<i>Finish date</i>	<i>Result (pCi/l)</i>	<i>Type of Test*</i>	<i>Comments</i>
-------------	--------------------	-------------------	--------------------	-----------------------	----------------------	-----------------

**Alpha Track monitors provide the long term average radon level 24 hours a day, 7 days a week for 6 - 7 months. That includes time when schools are closed and the ventilation system is off (nights, weekends and holidays).*

**Continuous monitors provide average hourly radon levels over 3 - 4 days. They allow us to see how the ventilation system affects the radon level. Continuous monitors were placed in all locations where Alpha Track monitors had a result at 4.0 pCi/l or higher.*